2024Energy Conservation and Demand Management Plan

July 1, 2024.

Table of Contents

Education Sector Background

Funding and Energy Management Planning 5

Asset Portfolios and Energy Management Planning 5

PART I: A REVIEW OF PROGRESS & ACHIEVEMENTS in the PAST FIVE YEARS 7

A. d Z } Œ [• • • š ... W } Œ š (} o] } 7

B. Energy Consumption Data for the Board 7

C. Weather Normalized Energy Consumption Values 8

D. Review of Previous Energy Conservation Goals and Achievements 9

Full Day Kindergarten (also known as FDK)

Before and After School Programs 10

Community Use of Schools 10

Community Hubs 10

Air Conditioning 10

Compliance with current Ontario Building Code (also known as OBC) 11

E. Cumulative Energy Conservation Goal 11

F.

Table of Figures

Table 1: Board's Asset Portfolio 7
Table 2: Metered Consumption Values 7
Table 3: Asset Portfolio Chart 8
Table 4: Weather Normalized Values 8
Table 5: Cumulative Energy Intensity Conservation Goal and Actual Energy Intensity 9
Table 6: Cumulative Energy Intensity Conservation Goal from Fiscal Year 2018 to 2019 through Fiscal Year 2022 to 2023 12
Table 7: Annual Energy Intensity Conservation Goals 16
Table 8: Cumulative Conservation Goal 16

- Administrative building
- Maintenance/warehouse facility
- Community Hubs

x Shared Site Use (For example: two or more boards share common areas and/or partnered with a municipality)
- Swimming pools
- Libraries
- Lighted sports fields
- Sports domes

Other Variables:

x Programs
- Child care
- Before/After School Programs
- Summer School
- Community Use
  - Outdoor ice rinks

x Occupancy
- Significant increase or decrease in number of students
- Significant increase in the hours of operation
- New programs being added to a site

x Air Conditioning
- Significant increase in air-conditioned space
- Portables

x Other

PART I: A REVIEW OF PROGRESS & ACHIEVEMENTS in the PAST FIVE YEARS

A. 7 K H % R D U G ¶ V $ V V H W 3 R U W I R O L R

The following table outlines the energy-related variables and metrics L Q W K H % R D U G ¶ V asset portfolio that changed from the baseline Fiscal Year 2017 to 2018 to the end of the five-year reporting period Fiscal Year 2022 to 2023.

Table 1: Board ¶ Asset Portfolio

Key Metrics	(Baseline Year) Fiscal Year 2017 to 2018	Fiscal Year 2022 to 2023	Variance
Total Number of Buildings	25	23	-2
Total Number of Portables/Portapaks	2	2	0
Total Floor Area	44,287.67	40348.56	-3,939.11
Average Operating Hours	50	50	0
Average Daily Enrolment	2,050.86	2,223.75	+172.89
% of Total Floor Area Air Conditioned	33	33	0
Number of Facilities with Mechanical Ventilation	6	10	4
Other Relevant Changes in the Operation of Assets: Click or tap here to enter text.			

B. Energy Usage Data for the Board

7 K H I R O O R Z L Q J W D E O H consumption values in the common unit of Equivalent Kilowatt Hours (ekWh) and Kilowatt Hours (kWh).

Table 2: Metered Usage Values

Utility	Fiscal Year 2017 to 2018 (Baseline year)	Fiscal Year 2022 to 2023
Total Electricity (kWh)	3,770,682	3,158,667
Total Natural Gas (ekWh)	7,421,397	4,966,010
Total Heating Fuel (Type 1 and 2) (ekWh)	0	0
Total Heating Fuel (Type 4 and 6) (ekWh)	0	0

[1] Metered consumption is the quantity of energy used and does not include a loss adjustment value (the quantity of energy lost in transmission).

Utility	Fiscal Year 2017 to 2018 (Baseline year)	Fiscal Year 2022 to 2023
Total Propane (ekWh)	0	0
Total District Heat (ekWh)	0	0
Total District Cool (ekWh)	0	0

C. Weather Normalized Energy Consumption Values

In Ontario, 25% to 35% of energy consumption for a facility is affected by weather.

To demonstrate the effect of weather, the following table shows the Weighted Average Heating Degree Days (HDD)[2] and Cooling Degree Days (CDD)[3] for the six most common Environment Canada weather stations in the Ontario education sector.

Table 3: Ontario Degree -days

Ontario Degree Days	Fiscal Year 2017 to 2018	Fiscal Year 2018 to 2019	Fiscal Year 2019 to 2020	Fiscal Year 2020 to 2021	Fiscal Year 2021 to 2022	Fiscal Year 2022 to 2023
HDD	3989	4196	3837	3696	3799	3,611
CDD	432	334	415	392	340	267

Table 4: Weather Normalized Values

D. Review of Previous Energy Conservation Goals and Achievements

In 2019, the Board set annual energy conservation goals for the following five fiscal years. The following table compares the Energy Intensity Conservation Goal with the Actual Energy Intensity Reduced for each year.

Table 5: Comparison of Energy Intensity Conservation Goal and Actual Energy Intensity Reduced

Fiscal Year	Conservation Goal ekWh/ft2	Conservation Goal ekWh/m2	Conservation Goal Percentage	Actual Energy Savings ekWh/ft2	Actual Energy Savings ekWh/m2	Actual Energy Percentage
2018 to 2019	0.12	1.19	0.59	-3.88	-41.81	14.77
2019 to 2020	3.41	34.11	16.83	0.43	4.67	-1.93
2020 to 2021	0.64	6.40	3.16	-1.74	-18.71	7.60
2021-2022	0.22	2.19	1.08	-1.54	-16.53	7.27
2022 to 2023	0.28	2.80	1.38	1.14	12.32	-5.85

NOTE TO READERS:

When reviewing annual Actual Energy Savings and Actual Energy Percentage across the five (5) years in the chart above,

- *f* IRU VFKRROV ZLWK WKHVH SURJUDPV WKH QXP
  operating hours would be significantly reduced
- Factors that increased consumption include:
  - Implementation of new health and safety factors in FY2021 through FY2023 to address pandemic issues, such as:
    - increased ventilation (intake of fresh air),
    - increased filtration requirements
    - expanded operating hours of HVAC equipment

A ERDUG¶V achievement in 2019 forecasted Conservation Goals may be limited by some or all the above factors.

In addition to the pandemic-related factors outlined above, there are a number of other IDFWRUV WKDW UHJXODUO\ LPSDFW D ERDUG¶V DELOLW\ WI including:

Before and After School Programs

Before-School and After-School Programs need a facilit \¶ Heating, Ventilation, and Air Conditioning (also known as HVAC) system to operate for an extended (a)6 (n)-3 (d)-3 (A)-4 (ir)5 ( )]T

ope

increased desire for schools to have air conditioning. Air conditioning significantly increases D I D F L e n e r g y U s e , specifically electricity consumption.

Compliance with current Ontario Building Code (also known as OBC)

Table 6: Cumulative Energy Intensity Goal from Fiscal Year 2018 to 2019 through Fiscal Year 2022 to 2023

Cumulative Energy Intensity	(ekWh/ft2)	(ekWh/m2)	Variance
Forecasted Cumulative Energy Intensity Conservation Goal of Fiscal Year 2018 to 2019 through Fiscal Year 2022 to 2023 6 R X U F H %20R19DRUaG (to V be input by Board)	-4.66	-46.69	
Forecasted Cumulative Energy Intensity Conservation Goal as a Percentage 6 R X U F H %20R19DRUaG (to V be input by Board)			-23.03

NOTE TO READERS:

Important Consideration - It takes a minimum of one full year after an energy management strategy has been implemented before an evaluation can measure the related actual energy savings achieved.

PART II ±ENERGY CONSERVATION and DEMAND MANAGEMENT PLAN for FISCAL YEAR 2022 to 2023 to FISCAL YEAR 2027 to 2028

Part II R X W O L Q H V W K H reduce energy consumption through renewable energy and energy management strategies including:

1. Design, Construction and Retrofit;
2. Operations and Maintenance; and lastly
3. Occupant Behavior.

Background

1. The Board has an energy management position which includes the following options.

    In-house including:

    a. Full time
    b. Part time
    c. Shared job function

    Contracted third party, or

    None

2. Energy Management Strategies

Energy management strategies fall into four key categories:

1. Renewable Energy
2. Design/Construction/Retrofit
3. Operations and Maintenance
4. Occupant Behaviour

Renewable Energy

Definition

Renewable energy is any source that can be used to power the electricity grid and includes:

- solar panels
- wind turbines, etc.

for any of the Board's Energy Conservation Goals for Fiscal Year 2024 to Fiscal Year 2028 explained in Appendix E, Calculating Renewable Energy.

C. Energy Efficiency Incentives

The Board applies to incentive programs to support the implementation of energy efficient projects on a regular basis.

Yes No

If yes, between Fiscal Year 2018 to 2019 and Fiscal Year 2022 to 2023, the Board has applied for incentive funding from different agencies to support the implementation of energy efficient projects.

The Board uses external resource

E. Demand Management

1. The Board uses the following method(s) to monitor electrical Demand:

   Invoices

   Real-time data

   Online data from the Local Distribution Company (LDC)

   Other:

2. The Board uses the following methodologies to cut down electrical Demand:

   Equipment scheduling

   Phased/staged use of equipment

   Demand-limit equipment

   Deferred start-

Press TAB to move to input area. Press UP or DOWN ARROW in column A to read through the document.

Design, Construction and Retrofit Strategies

	2018-2019	2019-2020	2020-2021	2021-2022	2022-2023
Lighting / Electrical	Investments in Energy Management Strategies	nvestment in Energy Management Strategies	Investment in Energy Management Strategies	Investment in Energy Management Strategies	Investment in Energy Management Strategies
High Efficiency Lighting Systems (D5020, D502001, D502003, D502004)	$ -	$ -	$ 1,161,332	$ -	$ -
Outdoor Lighting (D502004)	$ -	$ -	$ -	$ -	$ -
Occupancy Sensors (D5021, D5022)	$ -	$ -	$ 387,000	$ -	$ -
Daylight Harvesting	$ -	$ -	$ -	$ -	$ -
Dimming Switches					
Other (Describe)					

	2018-2019	2019-2020	2020-2021	2021-2022	2022-2023
HVAC	Investment in Energy Management Strategies	nvestment in Energy Management Strategies	Investment in Energy Management Strategies	Investment in Energy Management Strategies	Investment in Energy Management Strategies
Efficient Boilers (near condensing) (D3020, D302001, D302002)	$ -	$ -	$ -	$ -	$ -
High-efficiency Boilers (condensing) (D3020, D302001, D302002)	$ -	$ -	$ -	$ 500,000	$ 200,000
High-efficiency Boiler Burners (D3020)	$ -	$ -	$ -	$ -	$ -
Geothermal (D302099)	$ -	$ -	$ -	$ -	$ -
Heat Recovery/Enthalpy Wheels (D3090)	$ -	$ -	$ -	$ 4,056,983	$ 2,326,205
Economizers (D306002)	$ -	$ -	$ -	$ -	$ -
Energy Efficient HVAC systems (D3050,D3040)	$ -	$ -	$ 1,106,934	$ -	$ -
Energy Efficient Rooftop Units (D302098)	$ -	$ -	$ -	$ -	$ -
High Efficiency Domestic Hot Water (D2020)	$ -	$ -	$ -	$ -	$ -
Efficient Chillers and Controls (D3030, D303011, D303012)	$ -	$ -	$ -	$ -	$ -
High-efficiency Motors (D304007, D303011)	$ -	$ -	$ -	$ -	$ -
VFD (D302056)	$ -	$ -	$ -	$ -	$ -
Demand Ventilation (D3040)	$ -	$ -	$ -	$ -	$ -
Entrance Heater Controls (D302099)	$ -	$ -	$ -	$ -	$ -
Destratification Fans (D3090)					
Other (Describe)	$ -	$ -	$ -	$ -	$ -

	2018-2019	2019-2020	2020-2021	2021-2022	2022-2023
Controls	Investment in Energy Management Strategies	nvestment in Energy Management Strategies	Investment in Energy Management Strategies	Investment in Energy Management Strategies	Investment in Energy Management Strategies
Building Automation Systems - New (D3060)	$ -	$ -	$ -	$ -	$ -
Building Automation Systems - Upgrade (D3060)	$ -	$ -	$ -	$ -	$ -
Real-time energy data for operators to identify and diagnose building issues					
Voltage Harmonizers (D501001)					
Other (Describe)	$ -	$ -	$ -	$ -	$ -

	2018-2019	2019-2020	2020-2021	2021-2022	2022-2023
Building Envelope	Investment in Energy Management Strategies	nvestment in Energy Management Strategies	Investment in Energy Management Strategies	Investment in Energy Management Strategies	Investment in Energy Management Strategies
Glazing (B302006, B2020, B3021)	$ -	$ -	$ -	$ -	$ -
Increased Wall Insulation (B2010)	$ -	$ -	$ -	$ -	$ -
New Roof (B3010, B3020)	$ 365,212	$ 172,100	$ 882,516	$ -	$ 22,823
New Windows (B2020)	$ 328,538	$ -	$ -	$ -	$ -

Investments in Energy Management Strategies

Treatments	$ -	$ -	$ -	$ -	$ -
Shading Devices	$ -	$ -	$ -	$ -	$ -
Other (Describe)	$ -	$ -	$ -	$ -	$ -
Total Investment in Design, Construction and Retrofit Strategies	$ 693,75	$ 172,10	$ 3,537,78	$ 4,556,98	$ 2,549,02

Investments in Energy Management Strategies

Operations and Maintenance Strategies

	2018-2019	2019-2020	2020-2021	2021-2022	2022-2023
Policy and Planning	Investment in Energy Management Strategies	Investment in Energy Management Strategies	Investment in Energy Management Strategies	Investment in Energy Management Strategies	Investment in Energy Management Strategies
New School Design/Construction Guidelines and Specifications	$ -	$ -	$ -	$ -	$ -
Day and Night Temperature Guidelines for all Schools	$ -	$ -	$ -	$ -	$ -
Nighttime Blackout of Sites - Interior	$ -	$ -	$ -	$ -	$ -
Nighttime Blackout of Sites - Exterior	$ -	$ -	$ -	$ -	$ -
Procures Only Energy Star Certified Appliances	$ -	$ -	$ -	$ -	$ -
Preventative Maintenance (re-commissioning, coil cleaning, filter changes)					
Daylight Harvesting (servicing)	$ -	$ -	$ -	$ -	$ -
Demand Ventilation (servicing)	$ -	$ -	$ -	$ -	$ -
Water Leak Detection System					
Other (Commissioning - Re and Retro)	$ -	$ -	$ -	$ -	$ 83,135

	2018-2019	2019-2020	2020-2021	2021-2022	2022-2023
Energy Audits	Investment in Energy Management Strategies	Investment in Energy Management Strategies	Investment in Energy Management Strategies	Investment in Energy Management Strategies	Investment in Energy Management Strategies
Walk Through Audit	$ -	$ -	$ -	$ -	$ -
Engineering Audit	$ -	$ -	$ -	$ -	$ -
Other (Describe)					
Total Investment in Operations and Maintenance Strategies	$ -	$ -	$ -	$ -	$ 83,135

Investments in Energy Management Strategies

	Investment in Renewable Energy Technology ($)						
Type of Renewable Energy	Fiscal Year 2018-2019	Fiscal Year 2019-2020	Fiscal Year 2020-2021	Fiscal Year 2021-2022	Fiscal Year 2022-2023	Number of systems added	Capacity Added (kW)
Solar Photovoltaic	$ -	$ -	$ -	$ -	$ -		
Solar Air	$ -	$ -	$ -	$ -	$ -		
Solar Water	$ -	$ -	$ -	$ -	$ -		
Wind Turbine	$ -	$ -	$ -	$ -	$ -		
Biomass	$ -	$ -	$ -	$ -	$ -		
Other	$ -	$ -	$ -	$ -	$ -		
Total	$ -	$ -	$ -	$ -	$ -		

Investments in Energy Management Strategies

Summary of Investment by Type

	2018-2019	2019-2020	2020-2021	2021-2022	2022-2023	2018/2019-2022/2023
Total Investments in Energy Management Strategies FY 2012-13 to FY 2017-18	Investment in Energy Management Strategies	Investment in Energy Management Strategies	Investment in Energy Management Strategies	Investment in Energy Management Strategies	Investment in Energy Management Strategies	Total Investment in Energy Management Strategies
Design, Construction and Retrofit Investments Total	$ 693,750	$ 172,100	$ 3,537,782	$ 4,556,983	$ 2,549,028	11,509,643
Operations and Maintenance Investments Total	$ -	$ -	$ -	$ -	$ 83,135	83,135
Occupant Behaviour Investments Total	$ -	$ -	$ -	$ -	$ -	0
Renewable Energy Investments Total	$ -	$ -	$ -	$ -	$ -	0
Total Investment Per Fiscal Year	$ 693,750	$ 172,100	$ 3,537,782	$ 4,556,983	$ 2,632,163	11,592,778

Calculating Energy Conservation Goals for FY 2024 to FY 2028

Press TAB to move to input area. Press UP or DOWN ARROW in column A to read through the document.

Renewable Energy

Type of Renewable Energy	Define	Number of existing systems in asset portfolio (owned)	Fiscal Year 2023-2024	Fiscal Year 2024-2025	Fiscal Year 2025-2026	Fiscal Year 2026-2027	Fiscal Year 2027-2028	Fiscal Year 2023 - 2024	Fiscal Year 2024 - 2025	Fiscal Year 2025 - 2026	Fiscal Year 2026 - 2027	Fiscal Year 2027 - 2028	Total Size (kW)	Actual or Estimated Total Generation (ekWh)
Solar photovoltaic														0
Solar air														0
Solar water														0
Wind Turbine														0
Biomass														0
Other														0

End of Worksheet.

Calculating Energy Conservation Goals for FY 2024 to FY 2028

Design, Construction and Retrofit Strategies

		2023-2024		2024-2025		2025-2026		2026-27		2027-2028	2023/24-2027/28			
Lighting	**Quantity of Time that Measure will be in place (years)**	**Estimated Cost of Implementation**	**Estimated Annual Energy Savings from all projects (ekWh)**	**Estimated Cost of Implementation**	**Estimated Annual Energy Savings from all projects (ekWh)**	**Estimated Cost of Implementation**	**Estimated Annual Energy Savings from all projects (ekWh)**	**Estimated Cost of Implementation**	**Estimated Annual Energy Savings from all projects (ekWh)**	**Estimated Cost of Implementation**	**Estimated Annual Energy Saving (ekWh)**	**Estimated Total Accumulated Energy Savings (ekWh)**	**Energy Payback Period**	**% related to Electricity**	**% related to Natural Gas**
High Efficiency Lighting Systems (D5020, D502001, D502003, D502004)	30	$ -	-	$ -	-	$ -	-	$ -	-		-	-	7	100	0
Outdoor Lighting (D502004)	30	$ -	-	$ -	-	$ -	-	$ -	-		-	-	7	100	0
Occupancy Sensors (D5021, D5022)	10	$ -	-	$ -	-	$ -	-	$ -	-	$ -	-	-	5	100	0
Other (Describe)		$ -	-	$ -	-	$ -	-	$ -	-	$ -	-	-	0		100

		2023-2024		2024-2025		2025-2026		2026-27		2027-2028	2023/24-2027/28			
H.V.A.C.	**Quantity of Time that Measure will be in place (years)**	**Estimated Cost of Implementation**	**Estimated Annual Energy Savings from all projects (ekWh)**	**Estimated Cost of Implementation**	**Estimated Annual Energy Savings from all projects (ekWh)**	**Estimated Cost of Implementation**	**Estimated Annual Energy Savings from all projects (ekWh)**	**Estimated Cost of Implementation**	**Estimated Annual Energy Savings from all projects (ekWh)**	**Estimated Cost of Implementation**	**Estimated Annual Energy Savings from all projects (ekWh)**	**Estimated Total Accumulated Energy Savings (ekWh)**	**Energy Payback Period**	**% related to Electricity**	**% related to Natural Gas**
Efficient Boilers (near condensing) (D3020, D302001, D302002)	30	$ -	-	$ -	-	$ -	-	$ -	-	$ -	-	-	15	5	95
High-efficiency Boilers (condensing) (D3020, D302001, D302002	15	$ -	-	$ -	-	$ -	-	$ -	-	$ -	-	-	10	5	95
High-efficiency Boiler Burners (D3020)	10	$ -	-	$ -	-	$ -	-	$ -	-	$ -	-	-	5	5	95
Geothermal (D302099)	25	$ -	-	$ -	-	$ -	-	$ -	-	$ -	-	-	35	100	0
Heat Recovery/Enthalpy Wheels (D3090)	20	$ -	-	$ -	-	$ -	-	$ -	-	$ -	-	-	8	20	80
Economizers (D306002)	15	$ -	-	$ -	-	$ -	-	$ -	-	$ -	-	-	7.5	50	50
Energy Efficient HVAC systems (D3050,D3040)	35	$ -	-	$ -	-	$ -	-	$ -	-	$ -	-	-	75	50	50
Energy Efficient Rooftop Units (D302098)	25	$ -	-	$ 1,000,000	340,123	$ -	-	$ -	-	$ -	-	1,360,490	30	50	50
High Efficiency Domestic Hot Water (D2020)	10	$ -	-	$ 150,000	263,543	$ -	-	$ -	-	$ -	-	1,054,173	1		

Calculating Energy Conservation Goals for FY 2024 to FY 2028

Press TAB to move to input area. Press UP or DOWN ARROW in column A to read through the document.

Calculating Energy Conservation Goals for FY 2024 to FY 2028

Press TAB to move to input area. Press UP or DOWN ARROW in column A to read through the document.

Occupant Behaviour Strategies

		2023-2024		~~2019-2020~~ 2024-2025			2025-2026		2026-27		2027-2028		2023/24-2027/28	
Training and Education	Quantity of Time that Measure will be in place (years)	Estimated Cost of Implementation	Estimated Annual Energy Savings from all projects (ekWh)	Estimated Cost of Implementation	Estimated Annual Energy Savings from all projects (ekWh)	Estimated Cost of Implementation	Estimated Annual Energy Savings from all projects (ekWh)							

Calculating Energy Conservation Goals for FY 2024 to FY 2028

Press TAB to move to input area. Press UP or DOWN ARROW in column A to read through the documen

Conservation Goal

	FY 2023	
Total Building Area (includes portables) (m²)	40,349	**Enter from UCD. - use square meters**
Total Building Area (includes portables) (ft²)	434,308	**Enter from UCD - use square feet**
Energy Consumption for the board (ekWh)	8,124,678	**Enter from UCD**

1 ft² = 0.0929 m²